Commonwealth of Kentucky Division for Air Quality STATEMENT OF BASIS / SUMMARY

Conditional Major, Construction/Operating
Permit: F-25-027
Amazon Data Services, Inc.
4805 Aero Parkway
Florence, KY 41042
June 17, 2025
Stacie Daniels, P.E., Reviewer

SOURCE ID: 21-015-00271

AGENCY INTEREST: 178765

ACTIVITY: APE20250003

Table of Contents

SECTION 1 – SOURCE DESCRIPTION	2
SECTION 2 – CURRENT APPLICATION AND EMISSION SUMMARY FORM	3
SECTION 3 – EMISSIONS, LIMITATIONS AND BASIS	3
SECTION 4 – SOURCE INFORMATION AND REQUIREMENTS	7
SECTION 5 – PERMITTING HISTORY	8
SECTION 6 – PERMIT APPLICATION HISTORY	9
APPENDIX A – ARREVIATIONS AND ACRONVMS	9

Permit Statement of Basis/Summary

Page 2 of 9

Permit: F-25-027

SECTION 1 – SOURCE DESCRIPTION

SIC Code and descri	iption: 35	71, Electror	nic Computers			
Single Source Det.	□ Yes	⊠ No	If Yes, Affilia	ted Source AI:		
Source-wide Limit	⊠ Yes	□ No	If Yes, See Se	ection 4, Table A		
28 Source Category	□ Yes	⊠ No	If Yes, Catego	ory:		
County: Boone Nonattainment Area	. ⊠ N/A	\square PM ₁₀ \square	PM _{2.5} □ CO	\square NO _X \square SO ₂	□ Ozone	□ Lead
PTE* greater than 10 If yes, for what p □ PM ₁₀ □ PM _{2.5}	ollutant(s	s)?	•	⊠ Yes □ No		
PTE* greater than 250 tpy for any criteria air pollutant \square Yes \boxtimes No If yes, for what pollutant(s)? \square PM ₁₀ \square PM _{2.5} \boxtimes CO \square NO _X \square SO ₂ \square VOC						
PTE* greater than 1	0 tpy for	any single h	azardous air po	ollutant (HAP)	□ Yes ⊠ N	О
PTE* greater than 2	5 tpy for	combined H	IAP □ Yes	⊠ No		

<u>Description of Facility</u>:

Amazon Data Services, Inc. consists of a server rack assembly and testing operation, which has no air emissions, and fifteen 2.5 MW emergency generators. The server racks are distributed to data centers. Amazon refers to the facility as CVG-200 and CVG-300 or CVG200/300, as there are two locations on the same property in the same building.

^{*}PTE does not include self-imposed emission limitations.

Permit: F-25-027

SECTION 2 – CURRENT APPLICATION AND EMISSION SUMMARY FORM

Permit Number: F-25-027	Activity: APE20250003			
Application Received: May 28, 2025	Application Complete Date(s): June 17, 2025			
Permit Action: ⊠ Initial □ Renewal	☐ Significant Rev ☐ Minor Rev ☐ Administrative			
Construction/Modification Requested?	⊠Yes □No			
Previous 502(b)(10) or Off-Permit Chan	ges incorporated with this permit action □Yes ⊠No			

Description of Action:

The facility had previously been permitted as a minor source under 401 KAR 52:040 with seven 2.5 MW diesel-fired emergency generators. The permittee seeks to construct an additional eight emergency generators identical to the first seven, subject to regulations under 401 KAR 52:030, 40 CFR 60, Subpart IIII and 40 CFR 63, Subpart ZZZZ.

F-25-027 Emission Summary						
Pollutant	2024 Actual (tpy)	PTE F-25-027 (tpy)				
CO	0.17	22.83				
NOx	1.39	191.67*				
PT	0.01	1.50				
PM_{10}	0.01	1.50				
$PM_{2.5}$	0.01	1.50				
SO_2	0.00	0.14				
VOC	0.03	4.21				
Lead	0.00	0.00				
Greenhouse Gases (GHGs)						
Carbon Dioxide	104.51	14,685				
Methane	0.00	0.60				
Nitrous Oxide	0.00	0.12				
CO ₂ Equivalent (CO ₂ e)	104.85	14,733				
Hazardous Air Pollutants (HAPs)						
Combined HAPs: 0.00 0.14						

^{*}Limited to 90 tpy to preclude 401 KAR 52:020, Title V permits

Permit: F-25-027

SECTION 3 – EMISSIONS, LIMITATIONS AND BASIS

Emission Units 01-15 Emergency Generator Engines							
Pollutant	Emission Limit or Standard	Regulatory Basis for Emission Limit or Standard	Emission Factor Used and Basis	Compliance Method			
NO _x + NMHC	6.4 g/kW-hr	40 CFR 60.4205(b), referencing 40 CFR	NO _x : 291.6 lb/Mgal VOC: 6.4 lb/Mgal (Manufacturer)				
CO	3.5 g/kW-hr	60.4202(b)(2) referencing 40 CFR	34.7 lb/Mgal (Manufacturer)	Certified Engine			
PM	0.20 g/kW-hr	1039, Appendix I	2.3 lb/Mgal (Manufacturer)				

Emission Unit	Equipment	Fuel	Maximum Fuel Input (gal/hr)	Rated Capacity (HP)	Manufacture Date	Installation Date
01			175.3	3,634	7/2022	Q2 2023
02			175.3	3,634	7/2022	Q2 2023
03			175.3	3,634	7/2022	Q2 2023
04			175.3	3,634	10/2022	Q22023
05			175.3	3,634	9/2023	Q1 2024
06			175.3	3,634	9/2023	Q1 2024
07			175.3	3,634	10/2022	Q3 2023
08	Caterpillar 3516C	Diesel	175.3	3,634	10/2022	Proposed 2025
09			175.3	3,634		
10			175.3	3,634		
11			175.3	3,634		Duamagad
12			175.3	3,634	2024 F	Proposed
13			175.3	3,634		2025
14]		175.3	3,634]	
15			175.3	3,634		

2023 Certificate Number: PCPXL78.1NZS-009; Engine Family: PCPXL78.1NZS **2024** Certificate Number: RCPXL78.1NZS-030; Engine Family: RCPXL78.1NZS

Applicable Regulations:

401 KAR 60:005, Section 2(2)(dddd), 40 C.F.R. 60.4200 through 60.4219, Tables 1 through 8 (**Subpart IIII**), *Standards of Performance for Stationary Compression Ignition* (CI) *Internal Combustion Engines* (ICE), applicable to owners and operators of stationary CI ICE that commence construction after July 11, 2005, where the stationary CI ICE are manufactured after April 1, 2006, and are not fire pump engines. **401 KAR 63:002, Section 2(4)(eeee),** 40 C.F.R. 63.6580 through 63.6675, Tables 1a through 8, and

Appendix A (**Subpart ZZZZ**), *National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines* (RICE), applicable to stationary RICE at a major or area source of HAP emissions. The engine shall meet the requirements of 40 CFR 63, Subpart ZZZZ by meeting the requirements of 40 CFR 60, Subpart IIII.

Emission Units 01-15 Emergency Generator Engines

Comments:

The permittee shall use diesel fuel that meets the requirements of 40 CFR 1090.305 for nonroad diesel fuel.

The permittee shall operate and maintain the engines according to the manufacturer's emission-related written instructions, change only those emission-related settings that are permitted by the manufacturer, and meet the requirements of 40 CFR part 1068, as they apply.

There is no time limit on the use of the engines in emergency situations.

The permittee may operate the engines for maintenance checks and readiness testing for a maximum of 100 hours per calendar year; The engine may be operated for up to 50 hours per calendar year in non-emergency situations (counted as part of the 100 hours for maintenance and testing).

The permittee shall install a non-resettable hour meter to monitor and maintain records of each engine's hours of operation in emergency and non-emergency service on a monthly basis. The permittee shall record the time of operation of the engine and the reason the engine was in operation during that time.

The permittee shall monitor and maintain records of each engine's fuel usage (in gallons) on a monthly basis.

The emission factors from the manufacturer are provided in g/HP-hr and converted using the following equation:

$$EF\left(\frac{lb}{Mgal}\right) = \frac{EF\left(\frac{g}{HP - hr}\right) \times 3,634 \ HP}{453.6 \frac{g}{lh} \times 0.1753 \frac{Mgal}{hr}}$$

The SO₂ emission factor is from AP-42, Table 3.4-1. Greenhouse gas emission factors (CO₂, CH₄, and N₂O) are from Tables C-1 and C-2 to 40 CFR 98, Subpart C. All HAP emission factors are from AP-42, Tables 3.4-3 and 3.4-4 and converted using a higher heating value of 137,000 Btu/gal.

Permit Statement of Basis/Summary Permit: F-25-027

Page 6 of 9

SECTION 3 – EMISSIONS, LIMITATIONS AND BASIS (CONTINUED)

Testing Requirements\Results

N/A

Permit: F-25-027

SECTION 4 – SOURCE INFORMATION AND REQUIREMENTS

Table A - Group Requirements:

Emission and Operating Limit	Regulation	Emission Unit
90 tpy of NOx emissions	401 KAR 52:030, Federally-enforceable permits for nonmajor sources	Source- wide

Table B - Summary of Applicable Regulations:

Applicable Regulations				
401 KAR 60:005, Section 2(2)(dddd), 40 C.F.R. 60.4200 through 60.4219, Tables	EUs 01-			
1 through 8 (Subpart IIII), Standards of Performance for Stationary Compression	15			
Ignition Internal Combustion Engines				
401 KAR 63:002, Section 2(4)(eeee), 40 C.F.R. 63.6580 through 63.6675, Tables	EUs 01-			
1a through 8, and Appendix A (Subpart ZZZZ), National Emission Standards for	15			
Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion				
Engines				

<u>Table C – Summary of Precluded Regulations:</u>

N/A

Table D - Summary of Non Applicable Regulations:

N/A

Air Toxic Analysis

N/A

Single Source Determination

N/A

Permit Statement of Basis/Summary Permit: F-25-027

Page 8 of 9

SECTION 5 – PERMITTING HISTORY

Permit	Permit Type	Activity#	Complete Date	Issuance Date	Summary of Action	PSD/Syn Minor
S-23-061	Initial	APE20230001	8/16/2023	8/25/2023	Initial Construction Permit	N/A

Permit Statement of Basis/Summary

Page 9 of 9

Permit: F-25-027

SECTION 6 – PERMIT APPLICATION HISTORY

N/A

APPENDIX A – ABBREVIATIONS AND ACRONYMS

AAQS – Ambient Air Quality Standards

AP-42 – Compilation of Air Pollution Emission Factors from Stationary Sources

BACT – Best Available Control Technology

Btu — British thermal unit

CAM – Compliance Assurance Monitoring

CFR – Code of Federal Regulations

CO – Carbon Monoxide

CVG – Cincinnati & Northern KY International Airport

Division – Kentucky Division for Air Quality

EF – Emission Factor

ESP – Electrostatic Precipitator

EU – Emission Unit

g - Gram(s) gal - Gallons

GHG - Greenhouse Gas

HAP – Hazardous Air Pollutant

HF – Hydrogen Fluoride (Gaseous)

HP – HorsePower hr – Hour(s)

KAR – Kentucky Administrative Regulations

kW – Kilowatts KY – Kentucky lb – Pound

Mgal -1,000 Gallons

MSDS – Material Safety Data Sheets

mmHg – Millimeter of mercury column height

MW – MegaWatts

NAAQS – National Ambient Air Quality Standards

NESHAP – National Emissions Standards for Hazardous Air Pollutants

NMHC – Non-Methane HydroCarbons

NO_x – Nitrogen Oxides NSR – New Source Review PM – Particulate Matter

PM₁₀ — Particulate Matter equal to or smaller than 10 micrometers PM_{2.5} — Particulate Matter equal to or smaller than 2.5 micrometers

PSD – Prevention of Significant Deterioration

PTE — Potential to Emit rpm — Rotations per minute SO₂ — Sulfur Dioxide

TF – Total Fluoride (Particulate & Gaseous)

tpy – Tons Per Year

VOC – Volatile Organic Compounds