



Groundwater Math Study Guide

This study guide is intended to help students become more familiar with the variety of math equations within the Groundwater Treatment manual and exam.

Below is a chart of where math can be found in the training manual.

Chapter	Name	Page	Concept
2	Water Sources	24	Specific Capacity
		28	Conversions
3	Well Systems	50	$Q = A \times V$
4	Disinfection	65	Demand, Dosage, Residual
		66	Pounds and Dosage Formula Strength of Solution Math
6	Specialized Treatment	90	Langelier Saturation index
7	Storage	103	Area, Volume
		104	Conversions
8	Pipes and Services	127	Area and Volume Review
11	Meters	168	Water Demand and Loss Math
12	Basic Hydraulics	174	Flow Calculations $Q=A \times V$
		184	Pressure/Feet of Head
		191	C-Factor
		194	Equivalent C-Factor
13	Pumps	210	Horsepower Formulae

Work through each problem introduced in each chapter and the math questions (if any) at the end of each chapter.

Class I & II

1. Calculate the specific Capacity of a well which has the following characteristics:

Well Yield: 300 gpm, Static Water level: 45 feet, Pumping level: 80 feet

- A. 3.75 gpm/ft
- B. 6.66 gpm/ft
- C. 8.57 gpm/ft
- D. 10.59 gpm/ft

2. What is the volume of a Stand pipe measuring 15 feet in diameter and 29 feet tall?

- A. 3,532 gallons
- B. 4,710 gallons
- C. 26,423 gallons
- D. 38,313 gallons

3. 55 psi is equivalent to how many feet of head?

- A. 23.9 ft
- B. 52.8 ft
- C. 105.6 ft
- D. 127.0 ft

4. A bucket contains 7.5 gallons of water. How much would the water weigh?

- A. 56.1 lbs
- B. 62.6 lbs
- C. 75.0 lbs
- D. 92.5 lbs

5. Three miles of new 3 inch PVS pipe needs to be disinfected using calcium Hypochlorite (70%). How many pounds of calcium hypochlorite will be needed?

- A. 0.32 lbs
- B. 2.33 lbs
- C. 3.46 lbs
- D. 350.3 lbs

6. Water flows through a 3 inch diameter pipe at $0.45 \text{ ft}^3/\text{s}$. What is the velocity of the water?

- A. 9.18 ft/s
- B. 12.34 ft/s
- C. 15.25 ft/s
- D. 18.45 ft/s

7. A water plant treats the water with 3.8 mg/l chlorine. When the residual chlorine is checked in the point furthest from the plant in the distribution system it is 0.35 mg/L. What is the demand in this distribution system?

- A. 1.4 mg/l
- B. 3.45 mg/l
- C. 4.15 mg/l
- D. 5.2 mg/l

8. The projected water use for a new industrial plant coming to town is 1.2 MGD. What is the flow in gallons per minute?

- A. 79.0 gpm
- B. 538.6 gpm
- C. 833.4 gpm
- D. 1728.0 gpm

9. If a chemical has a specific gravity of 1.15, what would 1 gallon of the chemical weigh?

- A. 6.5 lbs
- B. 7.3 lbs
- C. 8.6 lbs
- D. 9.6 lbs

10. A water plant treated 22,386,000 gallons during the month of February. Records indicate that the amount of water billed was 20,345,670 gallons. What was the percent of non-revenue water or water loss for the plant?

- A. 9.1%
- B. 12.6%
- C. 14.5%
- D. 16.7%

11. The water plant treated 38,450 gallons of water during the last 24 hours using 1.5 pounds of chlorine. What is the dosage for that day?

- A. 0.47 mg/l
- B. 2.7 mg/l
- C. 4.7 mg/l
- D. 6.8 mg/l

12. Water from a well is being treated by a hypochlorinator. If the hypochlorinator is set at a pumping rate of 20 gallons per day and uses a 2% available chlorine solution, what is the chlorine dose if the well pump delivers 110 gpm?

- A. 1.5 mg/l
- B. 2.0 mg/l
- C. 2.5 mg/l
- D. 3.0 mg/l

13. A 50 gallon concentration tank is filled with 2 gallons of sodium hypochlorite (15% available chlorine) and 48 gallons of water. What is the % strength of this chlorine solution?

- A. 0.6%
- B. 1.1%
- C. 1.6%
- D. 2.2%

14. What is the flow rate of water moving through a 10 inch diameter pipe with a velocity of 2.5 feet per second?

- A. 0.96 ft³/sec
- B. 1.35 ft³/sec
- C. 4.63 ft³/sec
- D. 196.5 ft³/sec

15. When the well pump is running, Well #2 pumps 1.6 cu.ft/sec. The well drawdown has been measured at 47 feet. What is the specific capacity of Well #2?

- A. 2.9
- B. 8.6
- C. 11.5
- D. 15.3

16. The chlorine demand for your system is 2.6 mg/l. The operator treats 75,000 gallons of water with 3 pounds of chlorine gas. What will the chlorine residual be in the system?

- A. 1.5 mg/l
- B. 2.2 mg/l
- C. 3.4 mg/l
- D. 4.8 mg/l

17. A pump was found to deliver 15,748 gallons of water in 30 minutes into a cylindrical tank that measures 25 feet in diameter and stands 90 feet high. What is the pumping rate in gallons per minute?

- A. 524.9 gpm
- B. 675.5 gpm
- C. 778.4 gpm
- D. 990.6 gpm

18. Calculate the Langelier's Index for water having an actual pH of 7.6 and a saturation pH (pHs) of 7.85.

- A. + 0.25
- B. -0.25
- C. -2.5
- D. +7.25

19. A 500,000 gallon storage tank is to be disinfected using a 50 ppm chlorine bleach solution (bleach contains 5.25% available chlorine) with a specific gravity of 1.1. How many gallons of bleach will be required?

- A. 24 gallons
- B. 433 gallons
- C. 476 gallons
- D. 3971 gallons

20. The gauge at the bottom of an 80 foot tall standpipe reads 31 psi. What is the static head in feet?

- A. 13.4 feet
- B. 27.5 feet
- C. 71.6 feet
- D. 77.7 feet

Answer Key

- | | |
|-------|-------|
| 1. C | 11. C |
| 2. D | 12. C |
| 3. D | 13. A |
| 4. B | 14. B |
| 5. C | 15. D |
| 6. A | 16. B |
| 7. B | 17. A |
| 8. C | 18. B |
| 9. D | 19. B |
| 10. A | 20. C |

Class III & IV

21. What is the motor horsepower of a pump that is pumping at a flow of 2.8 cu.ft/sec while overcoming 50 feet of head? The pump efficiency is 80% and a motor efficiency is 85%.

- A. 16 MHP
- B. 20 MHP
- C. 23 MHP
- D. 29 MHP

22. The meter on a well was reading 21,456,298 gallons. 30 days later the meter was reading 38,398,132. What was the average daily flow in gpm?

- A. 0.547
- B. 392.2
- C. 564.7
- D. 564,727

23. A ground storage tank 30 ft. tall and 50 ft. in diameter is currently 35% full. One pump is filling the tank at a rate of 450 gpm while another pump is emptying the tank at 200 gpm. How long will it be before the tank is completely filled?

- A. 2.6 hours
- B. 8.7 hours
- C. 19.1 hours
- D. 47.7 hours

24. A polyphosphate solution is being added at the water plant for corrosion control. One gallon of this solution weighs 15 pounds. What is the specific gravity of this solution?

- A. 0.75
- B. 1.8
- C. 2.0
- D. 3.5

25. Water leaves the treatment plant at 300 gpm. If the water is flowing through a 4 inch line what is the flow rate in cubic feet per second?

- A. 0.057 cu.ft/sec
- B. 0.67 cu.ft/sec
- C. 7.84 cu.ft/sec
- D. 40.7 cu.ft/sec

26. A hypochlorinator lowers the level in a 36 inch diameter tank 16 inches in 4 hours. What is the hypochlorite feed rate?

- A. 422 gpd
- B. 565 gpd
- C. 4,230 gpd
- D. 697,570 gpd

27. What is the gauge pressure shown at the bottom of a tank 30 feet in diameter and 50 feet tall that is 75% full?

- A. 9.7 psi
- B. 16.2 psi
- C. 21.7 psi
- D. 27.1 psi

28. How long will it take to fill a 25,000 gallon tank if the pumping rate to fill the tank is 50 gpm?

- A. 0.35 days
- B. 0.75 days
- C. 1.25 days
- D. 2.75 days

29. A system has two wells pumping at the same time. Well #1 is pumping at 1.5 MGD and has a drawdown of 32 feet. Well # 2 is pumping at a rate of 1.8 cu.ft/sec and has a drawdown of 420 inches. What is the combined specific capacity?

- A. 25.3 gpm/ft
- B. 32.7 gpm/ft
- C. 45.0 gpm/ft
- D. 55.6 gpm/ft

30. A class 3 plant is adding 52 pounds of bleach at 7% available Chlorine to a flow of 950 gpm. What is the dosage?

- A. 0.32 ppm
- B. 0.67 ppm
- C. 4.55 ppm
- D. 7.56 ppm

31. What is the flow rate of water moving through a 6 inch pipe with a velocity of 2.2 feet per sec?

- A. 0.43 cu.ft/min
- B. 0.027 MGD
- C. 193 gpm
- D. 0.43 MGD

32. If the specific gravity of a bleach solution is 1.3, what will the weight of three gallons of this bleach be?

- A. 8.3 pounds
- B. 10.8 pounds
- C. 25.0 pounds
- D. 32.5 pounds

33. A plant is pumping water from a well in an 8 inch pipe. The pump is rated at 850 gpm and is running at 85% efficiency. The water is being treated with 42 pounds HTH at 65% available chlorine. What is the chlorine dosage being added to this water?

- A. 2.7 ppm
- B. 3.1 ppm
- C. 4.6 ppm
- D. 4.8 ppm

Answer Key

- 21. C
- 22. B
- 23. C
- 24. B
- 25. B
- 26. A
- 27. B

- 28. A
- 29. D
- 30. A
- 31. C
- 32. D
- 33. B

Class I & II Solved Equations

1. Formula used: *Specific Capacity = Flow, gpm ÷ Drawdown, ft*
Calculate: drawdown - Drawdown = Pumping level, ft - Static water level, ft
Drawdown, ft = 80 ft - 45 ft = 35 ft
Specific Capacity = 300 gpm ÷ 35 ft = 8.57 gpm/ft
2. Formula used: *Volume, gal + 0.785 X Diameter, ft x Diameter, ft X Height, ft x 7.48 gal/ft³*
Volume = 0.785 x 15 ft x 15 ft x 29 ft x 7.48 gal/ ft³ = 38,313 gal
3. Conversion used: *1 psi = 2.31 ft of head*
Going from unit on left of conversion chart to units on right so you multiply:
55 psi x 2.31 ft of head = 127.0 ft of head
4. Conversion used: *1 gallon = 8.34 pounds*
Going from unit on left of conversion chart to units on right so you multiply:
7.5 gallons of water x 8.34 pound / gallon = 62.6 pounds
5. Formula used: *Pounds = (ppm x 8.34 x MG) ÷ % purity Use decimal equivalent (% purity 100)*
Calculate the volume of the pipe in MG:
Change inches to feet: 3 / 12 = 0.25 ft
Volume, ft³ = 0.785 x 0.25 ft x 0.25 ft x (3 miles x 5280 ft)
Volume, ft³ = .785 x 0.25 ft x 0.25 ft x 15,840 ft = 777.15 ft³
Volume, gal = 777.15 ft³ x 7.48 gal / ft³ = 5,813 gal ÷ 1,000,000 = 0.00581 MG
Calculate pounds - Since this is new pipe regulations require it to be disinfected using 50 ppm:
Pounds = (50 ppm x 8.34 x 0.00581 MG) ÷ 0.70 = 2.42 ÷ 0.70 = 3.46 pounds

6. Formula used: *Velocity (V) = Flow (Q) ÷ Area (A)*

Find the area of the 3 in pipe: Convert inches to feet - 3 in ÷ 12 in = 0.25 ft

$$A, \text{ft}^2 = 0.785 \times 0.25 \text{ ft} \times 0.25 \text{ ft} = 0.049 \text{ ft}^2$$

Calculate Velocity:

$$V, \text{ft/sec} = 0.45 \text{ ft}^3/\text{sec} \div 0.049 \text{ ft}^2 = 9.18 \text{ ft/sec}$$

7. Formula used: *Demand - Dosage - Residual*

$$\text{Demand, mg/L} = 3.8 \text{ mg/L} - 0.35 \text{ mg/L} = 3.45 \text{ mg/L}$$

8. Conversion used: *1 MGD = 694.5 gpm*

$$1.2 \text{ MGD} \times 694.5 \text{ gpm} = 833.4 \text{ gpm}$$

9. Formula used: *Wt./gal = Specific Gravity x 8.34*

$$\text{Wt./gal} = 1.15 \times 8.34 = 9.59 \text{ or } 9.6 \text{ lbs}$$

10. Formula used:

$$\% \text{ water loss} = (\text{water lost, gallons} \div \text{water treated, gallons}) \times 100$$

Find water loss: water treated, gallons – water billed, gallons

$$\text{Water loss} = 22,386,000 \text{ gal} - 20,345,670 \text{ gal} = 2,040,330 \text{ gal}$$

$$\% \text{ water loss} = (2,040,330 \div 22,386,000) \times 100 = 0.091 \times 100 = 9.1\%$$

11. Formula used: *mg/L = pounds ÷ (8.34 x Flow, MGD)*

$$\text{Convert flow to MGD: } 38,450 \text{ gal} \div 1,000,000 = 0.038 \text{ MGD}$$

$$\text{Calculate mg/L: } \text{mg/L} = 1.5 \text{ lbs.} \div (8.34 \times 0.038) = 1.5 \text{ lbs.} \div 0.317 = 4.7 \text{ mg/L}$$

12. Formula used: $mg/L = pounds \div (8.34 \times Flow, MGD)$

Calculate pound of Chlorine used:

$$lbs. = 20 \text{ gal} \times 8.34 \times 0.02 = 3.34 \text{ lbs.}$$

Convert flow to MGD: 1

$$10 \text{ gpm} \div 694.5 \text{ gpm/1 MGD} = 0.16 \text{ MGD}$$

Calculate mg/l:

$$mg/L = 3.34 \text{ lbs.} \div (8.34 \times 0.16 \text{ MGD}) = 3.34 \text{ lbs.} \div 1.33 = 2.5 \text{ mg/L}$$

13. Formula used:

$$SOS, \% = (Gal, \text{ bleach} \times 8.34 \times \% \text{ purity (decimal)}) \div ((gal, \text{ water} + gal \text{ bleach}) \times 8.34) \times 100$$

Calculate SOS, %:

$$SOS, \% = ((2 \text{ gal} \times 8.34 \times 0.15) \div ((48 \text{ gal} + 2 \text{ gal}) \times 8.34)) \times 100$$

$$SOS, \% = (2.50 \div 417) \times 100 = 0.006 \times 100 = 0.6 \%$$

14. Formula used: $Flow, Q = Area, A \times Velocity, V$

Calculate the area of the 10 inch pipe:

$$\text{Convert the 10 inches into feet: } 10 \text{ in} / 12 \text{ in} = 0.83 \text{ ft}$$

$$\text{Area, } A = 0.785 \times 0.83 \text{ ft} \times 0.83 \text{ ft} = 0.54 \text{ ft}^2$$

Calculate the Flow:

$$\text{Flow, } Q = 0.54 \text{ ft}^2 \times 2.5 \text{ ft/sec} = 1.35 \text{ ft}^3/\text{sec}$$

15. Formula used: $Specific \text{ Capacity} = Flow, gpm \div Drawdown, ft$

$$\text{Convert flow from cu.ft/sec to gpm: } 1.6 \text{ cu.ft/sec} \times 448.8 \text{ gpm} = 718.08 \text{ gpm}$$

Calculate Specific Capacity of well:

$$\text{Specific Capacity} = 718.08 \text{ gpm} \div 47 \text{ ft} = 15.28 \text{ or } 15.3 \text{ gpm/ft}$$

16. Formula used: $Residual = dosage - demand$

Calculate the dosage in the system:

$$3 \text{ lbs.} \div (8.34 \times 0.075 \text{ MGD}) = 3 \div 0.626 = 4.79 \text{ or } 4.8 \text{ mg/L}$$

$$\text{Residual} = 4.8 \text{ mg/L} - 2.6 \text{ mg/L} = 2.2 \text{ mg/L}$$

17. Formula used: $Gallons\ pumped \div minutes\ pump\ runs = gpm$
Pump rate, gpm = $15,748\ gallons \div 30\ minutes = 524.9\ gpm$
18. Formula used: $pH(A) - pH(S) = \text{Langelier's Index}$ where, pH(A) is actual pH and pH(S) is calculated pH of Saturation:
 $7.6 - 7.85 = -0.25$
19. Calculate the number of pounds needed using the pounds formula:
 $lbs. = (50\ ppm \times 8.34 \times 0.5\ MGD) \div 0.0525 = 208.5 \div 0.0525 = 3,971.43\ lbs.$
- Calculate the number of gallons by dividing the lbs. by the weight of 1 gallon:
 $Gallons = 3,971.43\ lbs. \div (8.34 \times 1.1) = 3,971.43\ lbs. \div 9.17\ lbs./gal = 433.0\ gallons$
20. Convert PSI to feet of head:
Feet of head = $31\ psi \times 2.31\ feet\ of\ head/psi = 71.6\ feet\ of\ head$

Class III & IV Solved Equations

21. Formula used: $MHP = (Flow, gpm \times head, feet) \div (3960 \times Pump\ efficiency, \% \times Motor\ efficiency, \%)$
- Convert flow from cu.ft/sec to gpm:
 $Flow, gpm = 2.8\ cu.ft/s \times 448.8\ gpm/cu.ft/s = 1,256.64\ gpm$
- Convert pump efficiency and motor efficiency to decimals:
Pump efficiency = $80\% \div 100 = 0.80$
Motor efficiency = $85\% \div 100 = 0.85$
- Calculate Motor Horsepower:
 $MHP = (1,256.64\ gpm \times 50, feet) \div (3960 \times 0.8 \times 0.85) = 62,832 \div 2,672.4 = 23\ MHP$

Groundwater Math Study Guide

22. Formula used: $(\text{Ending flow} - \text{starting flow}) \div \text{number of days between readings} = \text{Avg. flow}$

Avg. Flow, gal/day = $(38,398,132 \text{ gal} - 21,456,298 \text{ gal}) \div 30 \text{ days} = 16,941,834 \text{ gal} / 30 \text{ days}$

Avg. Flow = $564,727.8 \text{ gal/day} \div 1,440 \text{ min/day} = 392.2 \text{ gpm}$

23. Calculate the volume of the tank in gallons:

Vol, gal = $0.785 \times 50 \text{ ft} \times 50 \text{ ft} \times 30 \text{ ft} \times 7.48 \text{ gal/ft}^3 = 440,385 \text{ gal}$

Tank is 35% full so it is 65% empty, calculate the empty volume:

Remaining volume = $440,385 \text{ gal} \times .65 = 286,250.25 \text{ gal}$

Flow coming in – flow going out: $450 \text{ gpm} - 200 \text{ gpm} = 250 \text{ gpm}$

Remaining tank volume \div net flow = minutes until tank is full

Minutes until filled = $286,250.25 \text{ gal} \div 250 \text{ gpm} = 1,145 \text{ minutes until filled}$

Hours to fill = $1,145 \text{ minutes} \div 60 \text{ min/hr} = 19.08 \text{ or } 19.1 \text{ hrs}$

24. Formula used: $\text{weight of solution} \div \text{weight of same quantity of water} = \text{Sp.Gr.}$

Sp.Gr. = $15 / 8.34 = 1.8$

25. Convert flow rate from gpm to ft^3/s – Ignore the 4 inch pipe

Flow, $\text{ft}^3/\text{s} = 300 \text{ gpm} \div 448.8 \text{ gpm/ft}^3/\text{s} = 0.67 \text{ ft}^3/\text{s}$

26. Calculate volume of liquid pumped in gallons in 4 hours

Convert inches to feet

Volume pumped, gal = $0.785 \times 3 \text{ ft} \times 3 \text{ ft} \times 1.33 \text{ ft} = 9.4 \text{ ft}^3 \times 7.48 \text{ gal/ft}^3 = 70.31 \text{ gallons/4 hrs}$

Gals/24 hr = $70.31 \times 6 = 421.9 \text{ or } 422 \text{ gpd}$

27. Calculate height of water in the 50 ft tank that is 75% full:

Height = $50 \times 0.75 = 37.5 \text{ feet}$

Convert feet of head to psi:

Psi = $37.5 \text{ feet of head} \times 0.433 = 16.2 \text{ psi}$

28. Calculate time required in minutes then convert to days:

$$\text{Time, min} = 25,000 \text{ gal} \div 50 \text{ gpm} = 500 \text{ minutes}$$

Convert to days:

$$\text{Time, days} = 500 \text{ min} \div 1440 \text{ min/day} = 0.347 \text{ or } 0.35 \text{ days}$$

29. Formula used: *Specific Capacity = Flow, gpm ÷ Drawdown, feet*

First, convert the flow from each well to gpm -

$$\text{Well \#1 Flow, gpm} = 1.5 \text{ MDG} \times 694.5 \text{ gpm/MDG} = 1,041.75 \text{ gpm}$$

$$\text{Well \#2} = 1.8 \text{ cu.ft/s} \times 448.8 \text{ gpm / cu.ft/s} = 807.84 \text{ gpm}$$

Calculate the drawdown for each well:

$$\text{Well \#1 Drawdown, ft} = 32 \text{ ft (no conversion needed)}$$

$$\text{Well \#2 Drawdown, feet} = 420 \text{ in} \div 12 \text{ in/ft} = 35 \text{ ft}$$

Calculate the specific capacity for each well and add them together:

$$\text{Specific Capacity, Well \#1} = 1,041.75 \text{ gpm} \div 32 \text{ ft} = 32.55 \text{ gpm/ft}$$

$$\text{Specific Capacity, Well \#2} = 807.84 \text{ gpm} / 35 \text{ ft} = 23.08 \text{ gpm/ft}$$

$$\text{Combined Specific Capacity} = \text{Specific Capacity, Well \#1} + \text{Specific Capacity, Well \#2}$$

$$\text{Combined Specific Capacity} = 32.55 + 23.08 = 55.64 \text{ or } 55.6 \text{ gpm/ft}$$

30. Formula used: *ppm = (lbs., added x %purity) ÷ (8.34 x flow, MGD)*

$$\text{First convert flow to MGD - Flow, MGD} = 950 \text{ gpm} \div 694.5 \text{ gpm/MDG} = 1.37 \text{ MGD}$$

Calculate the dosage, ppm:

$$\text{ppm} = (52 \text{ lbs.} \times 0.07) \div (8.34 \times 1.37 \text{ MGD}) = 3.64 \text{ lbs.} \div 11.42 = 0.32 \text{ ppm}$$

31. Formula used: $Q = A \times V$, where $Q = \text{flow}$, $A = \text{Area of pipe}$ and $V = \text{Velocity of the water}$

Calculate the area of the 6 inch pipe. 6 inches = 0.5 feet

$$\text{Area, ft}^2 = 0.782 \times 0.5 \text{ feet} \times 0.5 \text{ feet} = 0.196 \text{ ft}^2$$

Calculate the flow:

$$\text{Flow, ft}^3/\text{s} = 0.196 \text{ ft}^2 \times 2.2 \text{ ft/s} = 0.43 \text{ ft}^3/\text{s}$$

Convert the flow to gpm and MGD to find the right answer since $0.43 \text{ ft}^3/\text{s}$ is not one of the answers:

$$\text{Flow, MGD} = 0.43 \text{ ft}^3/\text{s} \times 1.55 \text{ MGD}/\text{ft}^3/\text{s} = 0.67 \text{ MGD}$$

$$\text{Flow, gpm} = 0.43 \text{ ft}^3/\text{s} \times 448.8 \text{ gpm}/\text{ft}^3/\text{s} = 193 \text{ gpm}$$

32. Formula used: $\text{lbs.} = \text{gal} \times 8.34 \times \text{Sp.Gr.}$

$$\text{lbs.} = 3 \text{ gal} \times 8.34 \text{ lbs./gal} \times 1.3 = 32.5 \text{ lbs.}$$

33. Formula used: $\text{ppm} = (\text{lbs., added} \times \% \text{purity}) \div (8.34 \times \text{flow, MGD})$

$$\begin{aligned} \text{Calculate flow in MGD} - \text{Flow, MGD} &= (85 \text{ gpm} \times 0.85) \div 694.5 = 722.5 \div 694.5 \\ &= 1.04 \text{ MGD} \end{aligned}$$

Calculate dosage, ppm:

$$\text{Ppm} = (42 \text{ lbs.} \times 0.65) \div (8.34 \times 1.04) = 27.3 \text{ lbs.} \div 8.67 = 3.14 \text{ or } 3.1 \text{ ppm}$$



Questions or Concerns?

The Kentucky Operator Certification Program provides training and issues certifications to ensure that individuals engaged in performing many of Kentucky's critical environmental activities are qualified and capable to perform their duties. Operator Certification staff are available to provide on-site assistance and training.

Online: eec.ky.gov/ocp

Phone: 502-564-3170

E-mail: kyocp@ky.gov



Kentucky Operator Certification Program

Certification and Licensing Branch

300 Sower Boulevard, 1st Floor, Frankfort, KY 40601

Assistance Hotline: kyocp@ky.gov | 502-564-3170