Alliance Water Resources, Inc. Operations Update

Martin County Water & Sanitation Districts

May 13, 2020



- Key Accomplishments to Date
- Employee Development
- Quarterly Goals
- Priority Issues
- Discussion/Questions

Key Accomplishments to Date

- Conducting monthly meter audits
- Created 90-day goals and accomplished 88% of them in the 1st quarter
- Created 90-day goals for the 2nd quarter
- New billing software purchased to be transitioned June 2020
- Repaired both paddle wheels in the oxidation ditch






Key Accomplishments to Date

- Repaired pump in Davis Branch (was being pumped daily)
- Have purchased critical operational equipment for regulatory compliance and leak detection
- Cleared blockage on Turkey Creek Sewer
- Developed Meter Reading and Billing SOP
- Repaired Crum Reservoir monument
- Installed 2nd pump at Turkey Booster Station
- 400ft of 4" main installed on Town Point Curve






Key Accomplishments to Date



- Purchased new lab equipment for both Wastewater plants
- New pump and float switches have been installed at the Inez Wastewater plant lift station allowing for redundancy and efficiency
- Tug Valley sludge canisters have been emptied
- Discharge line from Digester 1 at the Tug Valley plant has had a blockage removed



Employee Development

- PPE and Uniforms
 - ► Fall protection
 - Electrical Protective Gear
 - Safety Glasses
 - Hard Hats
 - Reflective Vests
 - Uniforms/Steel Toed Boots
- Training
 - Competent Person/Trench Safety
 - Flagger
 - Electrical Hazards/Arc Flash
 - Person Safety
 - Welding



FIRST QUARTER GOALS - COMPLETED

- New Billing Software purchased To be converted June 2020
- Every Meter Read Staff has gone from 19% discrepancies to less than 1%
- Meter Reading and Billing SOP has been created and is pending board approval
- Reconcile Billing for Meters All accounts have been corrected with proper customer information and information
- 2017 District Audit has been approved by the Board of Directors
- Security Deposits All security deposits have been identified and reconciled to the correct customers



FIRST QUARTER GOALS - COMPLETED

- Oxidation Ditch Rotors Both rotors have been repaired and are operating
- Grinder Pumps All grinder pumps have been caught up and staff are continuing to repair pumps as they fail
- Influent pump at the Inez WWTP has been installed creating redundancy
- Tank and Booster Station information was collected along with GPS coordinates and pictures
- All District owned vehicles have been inventoried with documentation
- Community project was identified but postponed due to COVID-19



SECOND QUARTER GOALS

- Customer Issues Database Develop, train staff and implement a database for collection of and responding to customer concerns
- New or Higher Licenses Identify 4 employees for new or higher licenses to meet of exceed requirements for the system
- ▶ **Update Fee Schedule** Update the list of all costs associated with Service Taps and Fees on new installations and send it to the board for approval
- Davis Branch Lift Station Develop a report with costs and 3 options for repairing and or replacing the lift station
- Cannot Locate Meters Locate and verify all meters that currently cannot or have not been located in some time
- Pumping to the Prison Written Plan/SOP for maximizing what can be pumped to the prison
- Water Plant Sludge Hauling Find a suitable location for hauling water plant sludge and submit land application permit



SECOND QUARTER GOALS

- Standard Specifications Written and submitted for Board review
- OPS Audits Visit each district owned site and conduct and audit
- Rebuild Drying Beds at INEZ WWTP Plan underway starting May 18th
- Multi-Customer Meters Get customers currently sharing a meter on their own tap
- Area Meters Have every customer associated with an area meter
- Organize and archive board minutes
- Install 8 new valves in strategic locations to improve distribution system
- Install 2 new cleanouts on the Turkey Creek sewer line

Water District Priority Issues

- Revenue Current deficit \$50k monthly
 - Audits completed and up to date
 - Evaluate fee schedule
 - ❖ Accurate Metering
 - Water Loss Program
- Water Loss
 - Accurate Metering
 - District Area meters located
 - Established program for leak detection
 - Theft of Water SOP and Board approved guidelines
- Radio Read Meters and Meter Replacement
- Water Plant Upgrades



Outstanding Priority Needs - Water

WATER PLANT (Highlighted issues addressed in Contract# 113-19-02)

- Refurbish treatment unit # 1; new valve vault & required piping
- Repair filter beds, filter divider walls, repair rake; all new filter media; tube settlers in unit #3; paint; check all bearings, motors and gear boxes
- Need 2 new filter level indicator probes (Filters #4 & #6); one level indicator for clearwell, ethernet card for High Service Pump #2
- Repair #3 filter drain valve
- Replace all 5 online turbidimeters along with software
- Sludge removal

Outstanding Priority Needs - Water

WATER PLANT (Highlighted issues addressed in Contract# 113-19-02)

- New lab equipment, CL17 chlorine analyzer, bench turbidimeter, chlorine meter, iron and manganese meter.
- Repair roof over the chemical storage room, leaks bad when it rains.
- New chemical feed pumps.
- Install doors that will lead into the valve vaults for unit #2 and unit #3, or a better ladder system.

Outstanding Priority Needs - Sanitation

INEZ WWTP

- One clarifier is out operation, it needs the skimmer repaired, the arms are broken. Need to identify the problem with the drainage system and repair.
- Drying beds need to be cleaned and disposed of (This project will begin May 18th).
- Backup generator needs to be serviced and new fuel tank installed.

Outstanding Priority Needs - Sanitation

TUG VALLEY WWTP

- Automatic valves SBR 2 automatic blow valve, future blower valve and SBR 1 decant valve need to be inspected by a service technician. Had a couple instances in low temperatures the valves failed to open and close properly.
- Backup generator needs serviced (outside service company)

COLLECTIONS SYSTEM

All Lift Stations need a minimum of two pumps

Questions?