

Kentucky Lead Workgroup Meeting
August 17, 2016
1:30 – 3:00 PM EST
Kentucky Division of Water
300 Sower Blvd
Frankfort, Kentucky 40601

1. Call Meeting to Order and Roll Call of Membership – Greg Heitzman
2. Introduce Guests
3. Approve Minutes of June 15, 2016
4. Presentation by Distribution Piping Sub-group – Bill Robertson
5. National Drinking Water Advisory Council Report on Lead – Greg Heitzman
6. Review Sub-groups Assignments and Schedule
7. Discuss Report Template
8. Open Discussion for Workgroup
9. Public Comment Period
10. Next Workgroup Meeting, 1:30 PM – September 21, 2016

**Drinking Water Advisory Council
Lead in Drinking Water (LIDW) Work Group
Draft Meeting Minutes
August 17, 2016**

In attendance: Greg Heitzman, Chair (BWK), Jennifer Burt (DPH), Tom Gabbard (DOW), Mike Gardner (BGMU), Ron Lovan (NKYW), Brad Montgomery (ACEC), Bill Robertson (PWWKY), Thomas Rockaway (UofL), Justin Sensabaugh (KYAW),

Liaisons: Gary Larimore (KRWA), Kay Sanborn (KYTN-AWWA)

Absent: Obe Cox (CCW), Rengao Song (LWC), Brian Thomas (MWD)

Division of Water (DOW): Sarah Gaddis, Samantha Kaiser, Todd Ritter

Public Attendees: Amber Agee (DPH), Lane Boldman (KCC), Samantha Morgan Faulkner (KYOAG-ORI), George Haynes II (DCA), Representative Dennis Horlander (LRC), Melissa A. Melton (RCAP), Jim Smith (CCW)

The meeting was held at the Kentucky Division of Water office, 300 Sower Blvd, Frankfort, KY and began at 1:35 p.m. EDT.

Call Meeting to Order and Roll Call of Membership

Chair Greg Heitzman led the roll call and noted the absent members.

Introduction of Guests

Guests introduced themselves.

Approve Minutes of June 15, 2016

Changes were made to June Meeting Minutes and the Workgroup approved the June Meeting Minutes by consensus.

Presentation by Distribution Piping Sub-group

Bill Robertson gave a Power Point presentation regarding water distribution and piping materials. Lead joints in cast iron piping (generally used prior to 1960) should not be a major area of focus for a source of lead contamination in drinking water. The primary source of lead in drinking water in distribution systems will be from lead service lines/piping, pipe fittings that contain lead, such as meters, brass/bronze fittings and valves and from lead based solder.

There is currently no easy method to inventory buried lead service lines. There are methods that require significant amounts of effort and are costly for utilities. He suggested that the first step in inventorying lead services lines is a detailed review of local plumbing codes, customer files, old system maps, old field books, purchasing records, board meeting minutes, etc. to try to determine the location of lead service lines, or the date that utilities phased out the use lead for service lines and replaced with newer materials, such as copper. Several cities, such as Paducah and Louisville report the use of copper as a substitute for lead, beginning in the 1930's. Some major US cities (i.e. Chicago) installed lead services into the 1980's.

The next step for inventory of lead service lines is using GIS systems to identify areas that have the greatest potential for lead service lines based on the age of the water main, age of homes, or other historical data, such as service line installation records. Utilities can then excavate adjacent to the water main and look at the service line material. This can be performed by conventional excavation with backhoe, or by using vacuum excavation or hand digging. Another suggested approach is testing the water for lead at each meter and also testing water at the tap inside the home, which is an indirect method but quicker and costs less. The data collected can be analyzed to determine if lead is detected between the water main and meter and between the meter and the customers tap. This method has been used with inconsistent results at best.

The workgroup discussed how utilities deal with lead service lines when they are found. Utilities are not required to, but most do, replace lead services lines once they are exposed during excavation in the field. There is a concern that during a partial lead service line replacement, disrupting the service line could cause elevated lead levels. Once the excavation process begins to find lead service lines, generalizing where they are located can be inaccurate. Lead service lines have been found in close proximity to excavated locations where no lead service line was found, often due to previous repairs on the service line or materials used by plumbers on premise plumbing. Every community is different and every location is different.

Each utility is responsible for their lead service line inventory; some utilities have acquired other water systems which makes it difficult to establish an inventory for those lines. Some utilities are waiting until regulators reach a decision regarding lead service line replacement. Other utilities (i.e. Louisville) have an active lead service line replacement program, replacing up to 1,500 per year. There is not a 'one size fits all' solution for eliminating lead service lines. Each utility should review its history of lead service lines, it's lead compliance record, and treatment methods to determine if a lead service line replacement program should be implemented.

Other issues that need to be addressed are how best to communicate to the public, elected officials, and regulators; how operators need be trained to identify lead service lines; and how to integrate these concepts into standard practice. The group also acknowledged the importance of public education and operator training.

National Drinking Water Advisory Council (NDWAC) Report of Lead

The NDWAC Report on Lead (hard copy provided to Workgroup members) is a good resource for the subgroups to use when preparing subgroup reports. Water industry leaders published this report in August 2015, prior to the Flint Michigan lead crisis and this allows a pre-Flint viewpoint on the lead service line issue.

Review Subgroups Assignments and Schedule

The Workgroup discussed the subgroup assignments and schedule. There will be no meeting in September. The Training subgroup will present at the meeting in October, and the Finance subgroup will present in November.

Discuss Report Template

The Workgroup was reminded to convert each presentation into a text document for its report. Mr. Heitzman will email the report template to the Workgroup members.

Open Discussion for Workgroup

The Workgroup discussed the U.S. EPA Drinking Water Workshop that will take place in Cincinnati, Ohio on August 23 – 25 and Kentucky Rural Water Association's Annual Conference August 22 – 24.

Public Comment Period

No public comments were made.

Next Workgroup Meeting

The Workgroup reached a consensus that there will be no meeting in September. The Workgroup decided the next meeting will be held on October 26, 2016 at 1:30 p.m. EDT at 300 Sower Boulevard, Frankfort, KY. All future meeting presentations will be pushed back by one month. Mr. Heitzman will update the Workgroup membership and schedule spreadsheet and forward to Workgroup members.

Adjournment

The meeting adjourned at 3:00 p.m. EDT.

DRAFT

**Drinking Water Advisory Council
Lead in Drinking Water (LIDW) Work Group
Draft Meeting Minutes
August 17, 2016**

In attendance: Greg Heitzman, Chair (BWK), Jennifer Burt (DPH), Tom Gabbard (DOW), Mike Gardner (BGMU), Ron Lovan (NKYW), Brad Montgomery (ACEC), Bill Robertson (PWWKY), Thomas Rockaway (UofL), Justin Sensabaugh (KYAW),

Liaisons: Gary Larimore (KRWA), Kay Sanborn (KYTN-AWWA)

Absent: Obe Cox (CCW), Rengao Song (LWC), Brian Thomas (MWD)

Division of Water (DOW): Sarah Gaddis, Samantha Kaiser, Todd Ritter

Public Attendees: Amber Agee (DPH), Lane Boldman (KCC), Samantha Morgan Faulkner (KYOAG-ORI), George Haynes II (DCA), Representative Dennis Horlander (LRC), Melissa A. Melton (RCAP), Jim Smith (CCW)

The meeting was held at the Kentucky Division of Water office, 300 Sower Blvd, Frankfort, KY and began at 1:35 p.m. EDT.

Call Meeting to Order and Roll Call of Membership

Chair Greg Heitzman led the roll call and noted the absent members.

Introduction of Guests

Guests introduced themselves.

Approve Minutes of June 15, 2016

Changes were made to June Meeting Minutes and the Workgroup approved the June Meeting Minutes by consensus.

Presentation by Distribution Piping Sub-group

Bill Robertson gave a Power Point presentation regarding water distribution and piping materials. Lead joints in cast iron piping (generally used prior to 1960) should not be a major area of focus for a source of lead contamination in drinking water. The primary source of lead in drinking water in distribution systems will be from lead service lines/piping, pipe fittings that contain lead, such as meters, brass/bronze fittings and valves and from lead based solder.

There is currently no easy method to inventory buried lead service lines. There are methods that require significant amounts of effort and are costly for utilities. He suggested that the first step in inventorying lead services lines is a detailed review of local plumbing codes, customer files, old system maps, old field books, purchasing records, board meeting minutes, etc. to try to determine the location of lead service lines, or the date that utilities phased out the use lead for service lines and replaced with newer materials, such as copper. Several cities, such as Paducah and Louisville report the use of copper as a substitute for lead, beginning in the 1930's. Some major US cities (i.e. Chicago) installed lead services into the 1980's.

The next step for inventory of lead service lines is using GIS systems to identify areas that have the greatest potential for lead service lines based on the age of the water main, age of homes, or other historical data, such as service line installation records. Utilities can then excavate adjacent to the water main and look at the service line material. This can be performed by conventional excavation with backhoe, or by using vacuum excavation or hand digging. Another suggested approach is testing the water for lead at each meter and also testing water at the tap inside the home, which is an indirect method but quicker and costs less. The data collected can be analyzed to determine if lead is detected between the water main and meter and between the meter and the customers tap. This method has been used with inconsistent results at best.

The workgroup discussed how utilities deal with lead service lines when they are found. Utilities are not required to, but most do, replace lead services lines once they are exposed during excavation in the field. There is a concern that during a partial lead service line replacement, disrupting the service line could cause elevated lead levels. Once the excavation process begins to find lead service lines, generalizing where they are located can be inaccurate. Lead service lines have been found in close proximity to excavated locations where no lead service line was found, often due to previous repairs on the service line or materials used by plumbers on premise plumbing. Every community is different and every location is different.

Each utility is responsible for their lead service line inventory; some utilities have acquired other water systems which makes it difficult to establish an inventory for those lines. Some utilities are waiting until regulators reach a decision regarding lead service line replacement. Other utilities (i.e. Louisville) have an active lead service line replacement program, replacing up to 1,500 per year. There is not a 'one size fits all' solution for eliminating lead service lines. Each utility should review its history of lead service lines, it's lead compliance record, and treatment methods to determine if a lead service line replacement program should be implemented.

Other issues that need to be addressed are how best to communicate to the public, elected officials, and regulators; how operators need be trained to identify lead service lines; and how to integrate these concepts into standard practice. The group also acknowledged the importance of public education and operator training.

National Drinking Water Advisory Council (NDWAC) Report of Lead

The NDWAC Report on Lead (hard copy provided to Workgroup members) is a good resource for the subgroups to use when preparing subgroup reports. Water industry leaders published this report in August 2015, prior to the Flint Michigan lead crisis and this allows a pre-Flint viewpoint on the lead service line issue.

Review Subgroups Assignments and Schedule

The Workgroup discussed the subgroup assignments and schedule. There will be no meeting in September. The Training subgroup will present at the meeting in October, and the Finance subgroup will present in November.

Discuss Report Template

The Workgroup was reminded to convert each presentation into a text document for its report. Mr. Heitzman will email the report template to the Workgroup members.

Open Discussion for Workgroup

The Workgroup discussed the U.S. EPA Drinking Water Workshop that will take place in Cincinnati, Ohio on August 23 – 25 and Kentucky Rural Water Association's Annual Conference August 22 – 24.

Public Comment Period

No public comments were made.

Next Workgroup Meeting

The Workgroup reached a consensus that there will be no meeting in September. The Workgroup decided the next meeting will be held on October 26, 2016 at 1:30 p.m. EDT at 300 Sower Boulevard, Frankfort, KY. All future meeting presentations will be pushed back by one month. Mr. Heitzman will update the Workgroup membership and schedule spreadsheet and forward to Workgroup members.

Adjournment

The meeting adjourned at 3:00 p.m. EDT.

DRAFT

KENTUCKY LEAD WORKING GROUP

DISTRIBUTION / PIPING SUBGROUP PRESENTATION
 LEAD PRESENTATION
 AUGUST 17, 2014

PLUMBING SUBGROUP MEMBERS: MICK PETERSON, PAUL CLAYTON, PHILIPPO TORRE, JENNIFER BOYD


DISTRIBUTION / PIPING SUBGROUP PRESENTATION OVERVIEW

- DISTRIBUTION SYSTEM PIPING MATERIALS
- LEAD IN PIPING MATERIALS
- SDWA / LEAD AND COPPER RULE IMPACT ON PIPING MATERIALS
- SYSTEM INVENTORY
- GETTING THE LEAD OUT

DISTRIBUTION SYSTEM MATERIALS IN USE THROUGHOUT MODERN HISTORY

- WOOD
- LEAD
- CAST IRON – LEAD JOINT – SLIP JOINT – MECHANICAL JOINT
- ASBESTOS CEMENT – AC – TRANSITE
- DUCTILE IRON – SLIP JOINT (PUSH ON) – MECHANICAL JOINT
- PVC – SLIP JOINT – FUSED – GLUED
- HDPE – FUSED – MECHANICAL JOINT
- STEEL – WELDED
- GALVANIZED STEEL
- COPPER
- BRASS
- CONCRETE

LEAD JOINT CAST IRON PIPE



WHY WAS LEAD PIPE USED?

- FLEXIBLE
- DURABLE
- EASY TO WORK WITH
- NOT SUBJECT TO PIN HOLE LEAKS
- PLUMBERS PROTECTING THEIR JOBS

REGULATION OF LEAD IN PLUMBING

- 1986 – CONGRESS AMENDED THE SAFE DRINKING WATER ACT – PROHIBITED THE USE OF PIPES, SOLDER OR FLUX THAT WAS NOT "LEAD FREE" IN PLUMBING OF FACILITIES FOR HUMAN CONSUMPTION. LEAD FREE WAS NO MORE THAN 8% LEAD IN PIPE AND .2% IN SOLDER OR FLUX.
- 1996 – CONGRESS AMENDED THE SAFE DRINKING WATER ACT – REQUIRED PLUMBING FITTINGS AND FIXTURES TO BE IN COMPLIANCE WITH VOLUNTARY LEAD LEACHING STANDARDS. ALSO PROHIBITED SELLING ANY PIPE, FITTING OR FIXTURE THAT WAS NOT LEAD FREE.

REGULATION OF LEAD IN PLUMBING

- 2011 – CONGRESS PASSED THE REDUCTION OF LEAD IN DRINKING WATER ACT – REVISED THE DEFINITION OF "LEAD FREE" BY LOWERING THE MAXIMUM CONTENT OF LEAD IN PIPE TO .25% AND ELIMINATED THE REQUIREMENT FOR LEAD FREE PRODUCTS TO BE IN COMPLIANCE WITH VOLUNTARY LEAD LEACHING STANDARDS.
- 2011 – 2013 – EXEMPTED REQUIREMENTS TO BE "LEAD FREE" FOR PLUMBING FIXTURES USED FOR NON-POTABLE USE, FIRE HYDRANTS, DISTRIBUTION SYSTEM VALVES, SERVICE SADDLES, ETC.

REGULATION OF LEAD IN WATER LEAD AND COPPER RULE

- PRIOR TO 1991 – LEAD LIMIT WAS SET AT 50 PPB AT THE DISTRIBUTION SYSTEM ENTRY POINT
- 1991 – LEAD AND COPPER RULE – ESTABLISHED A MCLG OF 0 PPB, ESTABLISHED TESTING REQUIREMENTS AND FREQUENCY, ESTABLISHED AN ACTION LEVEL FOR LEAD OF 15 PPB, IDENTIFIED TREATMENT TECHNIQUE TO REDUCE CORROSION OF LEAD IN THE DISTRIBUTION SYSTEM
- 2000 – MINOR CORRECTIONS TO THE LEAD AND COPPER RULE – ADDRESS IMPLEMENTATION ISSUES ARISING FROM LEGAL CHALLENGE

REGULATION OF LEAD IN WATER LEAD AND COPPER RULE

- 2004 – MINOR REVISIONS TO EARLIER REVISIONS – CLEANED UP UNADVERTENTLY DROPPED TEXT FROM PREVIOUS REVISION
- 2007 – REVISIONS TO RULE (SHORT TERM REVISIONS) – THESE REVISIONS ADDRESS MONITORING, TREATMENT, CUSTOMER AWARENESS AND LEAD SERVICE LINE REPLACEMENT, THE REVISION ENSURED CUSTOMERS RECEIVED MEANINGFUL, TIMELY AND USEFUL INFORMATION.



? THE BIG QUESTION ? LEAD SERVICE LINE INVENTORY

- RIGHT NOW NO EASY METHOD EXISTS TO INVENTORY LEAD SERVICE LINES
- ONE POSSIBLE APPROACH IS A MULTI-STEP APPROACH WITH EACH SUBSEQUENT STEP REQUIRING MORE EFFORT AND COST FROM THE UTILITY
- WE CAN START WITH A DETAILED REVIEW OF LOCAL PLUMBING CODES, CUSTOMER FILES, OLD SYSTEM MAPS, OLD FIELD BOOKS, PURCHASING RECORDS, BOARD MEETING MINUTES, ETC. TO TRY AND DETERMINE THE LOCATION OF LEAD SERVICE LINES OR THE LAST DATE THAT LEAD SERVICE LINES WERE INSTALLED IN THE DISTRIBUTION SYSTEM
- WE CAN THEN USE OUR GIS SYSTEM TO IDENTIFY AREAS THAT HAVE THE GREATEST POTENTIAL FOR LEAD SERVICE LINES BASED ON THE AGE OF THE WATER MAIN
- FINALLY WE CAN EXCAVATE ADJACENT TO THE METER OR AT THE CORPORATION STOP AND LOOK AT THE SERVICE LINE MATERIAL

? THE BIG QUESTION ? LEAD SERVICE LINE INVENTORY

- ANOTHER POSSIBLE APPROACH IS TO TEST THE WATER AT EACH METER FOR LEAD. THIS WOULD BE AN INDIRECT METHOD BUT QUICKER AND AT LESS COST.
- THE WATER RESEARCH FOUNDATION HAS AN RFP FOR PROJECTS THAT WILL INVESTIGATE SERVICE LINE MATERIAL IDENTIFICATION TECHNIQUES

LEAD SERVICE LINE INVENTORY

CUSTOMER RECORDS







SYSTEM MAPPING





OLD PROJECT BOOKS



LEAD SERVICE LINE INVENTORY





LEAD SERVICE LINE INVENTORY

PREPARATION FOR VACUUM EXCAVATION **VACUUM EXCAVATION** **PLASTIC SERVICE LINE**

The first photo shows two workers in safety gear standing in a yard, preparing the site. The second photo shows a vacuum excavation machine being used to dig a hole. The third photo shows a close-up of a white plastic pipe being located within the excavated hole.

LEAD SERVICE LINE INVENTORY

EXCAVATION IN PAVEMENT **LEAD SERVICE LINE**


The first photo shows a worker in a high-visibility vest using a hand tool to break up asphalt pavement. The second photo shows a close-up of a lead pipe being located in a deep, narrow excavation.

LEAD "GOOSE NECK OR PIG TAIL"

The photo shows a lead pipe that has bent sharply at a 90-degree angle, forming a 'goose neck' or 'pig tail' shape. This is a common issue with lead pipes due to their weight and brittleness over time.

LEAD SERVICE LINES

The first photo shows a lead pipe being excavated from a deep hole. The second photo shows a close-up of a lead pipe with a sharp bend, similar to the 'goose neck' shown in the previous slide.



HOW DO WE ADDRESS LEAD SERVICE LINES ?

- DO NOTHING
- CONTROL CORROSION / TEST AND MONITOR
- ADD PHOSPHATE / TEST AND MONITOR
- REPLACE ALL LEAD "PIG TAILS" AND SERVICES



Available Water Services & Neofit's Advantages

Project Name: [Redacted]

Date of water shut-off: [Redacted]

Hours: 8:00 AM to 4:00 PM

30 Days for the most 30-day project completion. 21 days for a 21-day project.

2 Years for the most 2-year project completion. 1 year for a 1-year project.

WATER

Take lead out of contact with drinking water with the Neofit System

Neofit System Advantages

- Lead-free, NSF 61 certified, NSF 373 approved, NSF 61 approved, NSF 373 approved, NSF 61 approved, NSF 373 approved
- NSF 61 certified, NSF 373 approved, NSF 61 approved, NSF 373 approved
- NSF 61 certified, NSF 373 approved, NSF 61 approved, NSF 373 approved

Call us at 1-800-368-5888

CORROSION CONTROL IS THIS THE ANSWER ?

- CORROSION CONTROL WAS REVIEWED BY RENGAO SONG AT OUR LAST MEETING.
- IF WE IMPLEMENT CORROSION CONTROL WE MUST EVALUATE THE DISTRIBUTION SYSTEM TO DETERMINE THE BEST APPROACH FOR EACH SYSTEM. CORROSION CONTROL WITHOUT PHOSPHATES USUALLY RESULTS IN HIGH PH WATER LEAVING THE WATER TREATMENT PLANT.
- ONCE IMPLEMENTED, WE MUST MONITOR THE DISTRIBUTION SYSTEM TO MAKE SURE THE SELECTED APPROACH IS EFFECTIVE. IF NOT EFFECTIVE, WE CAN MODIFY OUR APPROACH.

PHOSPHATE ADDITION IS THIS THE MIRACLE CHEMICAL ?

- POLY-PHOSPHATE WILL NOT PREVENT CORROSION. IT WILL HELP WITH "CLEANING UP" THE DISTRIBUTION SYSTEM.
- ORTHO-PHOSPHATE WILL HELP PREVENT CORROSION IN THE DISTRIBUTION SYSTEM BY COATING THE INTERIOR OF PIPES.
- PHOSPHATE ADDITION WORKS BEST AT A MODERATE PH OF 7.4 TO 7.8.
- TYPICAL DOSES OF PHOSPHATE RANGE FROM .6 MG/L TO 2.0 MG/L.

CORROSION CONTROL

- EVERY SYSTEM IS UNIQUE AND WHAT WILL WORK FOR ONE SYSTEM MAY OR MAY NOT WORK FOR ANOTHER. EACH SYSTEM WILL HAVE TO BE EVALUATED TO DETERMINE THE BEST APPROACH FOR CORROSION CONTROL.
- DISTRIBUTION SYSTEM MONITORING IS ESSENTIAL FOR SUCCESS. IMPLEMENTATION IS NOT AS SIMPLE AS HOOKING UP A CHEMICAL FEED PUMP, HAVING THE CHEMICAL SALES PERSON SET THE DOSE AND YOUR DONE.
- UPPER MANAGEMENT MUST BE INVOLVED AND COMMITTED TO SUCCESS. CORROSION CONTROL CAN BE EXPENSIVE AND AT TIMES FRUSTRATING.

QUESTIONS ?

LEAD IN DRINKING WATER WORK GROUP
 300 Sower Blvd, Frankfort, KY 40601
 August 17, 2016
 WORK GROUP MEMBER SIGN-IN SHEET

Name	Agency/Organization	Email Address	Phone number
Justin Sensabaugh	Kentucky Aquatics.com	justin.sensabaugh@kentwater.com	851-268-6342
Jim Smith	Chroll CO. WATER	ccox@ccwb.com	502-347-9470
GARY LARIMORE	Ky Rural Water	G.Larimore@krwva.org	270-845-2291
BRAD MONTGOMERY	ACEC-KY (GRW)	bradmontgomery@grwinc.com	(855) 223-3999
BILL ROBERTSON	PAUCAN KLATER	brobertson@pauwkf.com	270-217-3071
Greg Hutzman	Blue water	ghutzman@bluewaterky.com	502-533-5073
Mike Gardner	Bevill	mgardner@bevill.com	770-792-4366
Tom Cocksaw	UofC	tomc@uofc.edu	502/852-3272
Mejissa A Melton	RCAP	mam@capky.org	502.875.5863
Jennifer Burt	DOH	jennifer.a.burt@ky.gov	502-564-4537
Ron	NKY WATER	Rcoleman@nkywater.org	502-564-5087