

This study guide is intended to help students become more familiar with the variety of math equations within the Surface Water Treatment manual and exam.

Below is a chart of where math can be found in the training manual.

Chapter	Name	Page	Concept
4	Coagulation	66	Conversions
6	Sedimentation	90	Area/ volume
7	Alternative Treatment	105	Weir Overflow Rate
7	Alternative Treatment	105	Detention Time
7	Alternative Treatment	106	Surface Overflow Rate
7	Alternative Treatment	106	Lbs of Chemical
8	Filtration	147	Flow $Q = AxV$
8	Filtration	148	Filtration and Backwash Rate
8	Filtration	149	Alternative Filtration Rate
9	Disinfection	196	Dosage = Demand - Residual
9	Disinfection	203	lbs formula and % purity
9	Disinfection	208	Specific Gravity
9	Disinfection	209	Strength of Solution
14	Stabilization	248	Langelier Saturation Index

Work through each problem introduced in each chapter and the math questions (if any) at the end of each chapter.

Class I & II

1. What is the flow rate of wastewater, in gallons per minute, through a plant that treats 1.5 million gallons of water per day?

- A. 2.3 gpm
- B. 11.22 gpm
- C. 673 gpm
- D. 1042 gpm

2. What is the flow rate of wastewater, in gallons per minute, through a plant that treats 2 million gallons of water during an 8 hour shift?

- A. 1389 gpm
- B. 2693 gpm
- C. 4167 gpm
- D. 5987 gpm

3. What is the volume of pipe that has an inside diameter of 8 inches and is 1,500 feet long?

- A. 50.24 ft³
- B. 528.6 ft³
- C. 673.3 ft³
- D. 788.9 ft³

4. What volume in gallons would this pipe hold?

5. What is the weir overflow rate of a circular sedimentation basin that has a circumference at the weir of 300 feet? Assume that flow into the basin is at 400 gpm and the basin is full.

- A. 0.75 gpm/ft
- B. 1.33 gpm/ft
- C. 1.5 gpm/ft
- D. 2.6 gpm/ft

6. What is the weir overflow rate of a circular sedimentation basin that has a radius of 30 feet? Assume that flow into the basin is at 150 gpm and the basin is full.

- A. 0.8 gpm/ft
- B. 4.77 gpm/ft
- C. 0.32 gpm/ft
- D. 3.75 gpm/ft

7. What is the detention time of a rectangular settling basin which measures 15' wide by 25' long by 10' deep and receives a flow of 250 gpm?

- A. 11.2 minutes
- B. 15 minutes
- C. 112.2 minutes
- D. 900 minutes

8. How would you solve the previous question if the answers were in hours instead of minutes ?

9. How would you solve the previous question if the flow was 0.4 MGD?

10. What is the surface overflow rate of a sedimentation basin if the basin measures 10 feet by 12 feet and is 8 ft deep and the flow rate into it is 700 gpm?

- A. 0.73 gpm/ft²
- B. 5.8 gpm/ft²
- C. 14.5 gpm/ft²
- D. 20.2 gpm/ft²

11. What would be surface overflow rate of the above basin if the inflow was given as 2 ft³/sec?

12. A water treatment plant used 32 pounds of alum to treat 1.2 million gallons of water during a 24 hour period. What is the polymer dosage?

- A. 0.32 mg/L
- B. 3.2 mg/L
- C. 26.6 mg/L
- D. 38.4 mg/L

13. Water flows through a 10" inside diameter pipe at a rate of 1.3 ft³/s. What is the velocity of the water flowing through this pipe?

- A. 2.4 ft/s
- B. 1.99 ft/s
- C. 0.79 ft/s
- D. 0.1 ft/s

14. What would the velocity of the water be in the above pipe if the flow rate was 400 gpm?

15. The hydraulic grade line is located 150 feet above a point in the pipeline. What is the pressure at that point in the pipeline?

- A. 17.9 psi
- B. 20 psi
- C. 65 psi
- D. 351 psi

16. If your standpipe is 95 feet tall and 35 feet in diameter, what would a pressure gauge read if the gauge was 5 feet above grade?

- A. 37 psi
- B. 39 psi
- C. 41 psi
- D. 43 psi

17. A filter has a surface area of 240 square feet and filters 900 gpm. What is the filtration rate?

- A. 3.75 gpm/ft²
- B. 7.5 gpm/ft²
- C. 0.26 gpm/ft²
- D. 0.1 gpm/ft²

18. What would be the filtration rate in Question #15 if the flow was given as 2.1 MGD?

19. The chlorine demand of a certain water system is 3.0 mg/L. The plant treats 250,000 gallons of water with 10 pounds of chlorine gas per day. What will the chlorine residual be?

- A. 4.7 mg/L
- B. 7.7 mg/L
- C. 0.9 mg/L
- D. 1.8 mg/L

20. How many pounds of 5.25% bleach would be needed to treat 900,000 gallons of water at a dosage of 3 ppm?

- A. 428.9 pounds
- B. 42.8 pounds
- C. 22.5 pounds
- D. 11.25 pounds

Answer Key

- | | |
|-------------------|----------------------------------|
| 1. D | 11. 7.48 gallons/ft ² |
| 2. C | 12. B |
| 3. B | 13. A |
| 4. 3953.9 gallons | 14. 1.65 ft/s |
| 5. B | 15. C |
| 6. A | 16. B |
| 7. C | 17. A |
| 8. 1.87 hrs | 18. 6.07 gpm/ft ² |
| 9. 101 minutes | 19. D |
| 10. B | 20. A |

Class III & IV

21. If the water during your backwash cycle rises at a rate of 6 inches in 3 minutes, what is the backwash rate?

- A. 0.8 gpm/ft²
- B. 1.25 gpm/ft²
- C. 3.2 gpm/ft²
- D. 3.6 gpm/ft²

22. Calculate the theoretical detention time through a treatment plant having a flow rate of 5.2 MGD and the following basin sizes:

flocculator = 20' X 60' X 15'

sedimentation = 40' X 90' X 15'

- A. 149 minutes
- B. 220 minutes
- C. 298 minutes
- D. 356 minutes

23. A water treatment plant used 110 pounds of cationic polymer to treat 6.9 million gallons of water during a 24 hour period. Specific gravity of the polymer is 2.47. What is the polymer dosage?

- A. 0.77 mg/L
- B. 1.2 mg/L
- C. 1.5 mg/L
- D. 1.9 mg/L

24. In the new chemical catalogue for 2020, Alum that was \$0.08 a pound has the price increased by 12%. Polymer was \$0.22 a pound but has just undergone a 37% increase and electrical energy got a 41% increase from it's current \$0.08 kWh. What are the new prices of alum, polymer and electricity?

- A. \$0.06, \$0.07, \$0.03
- B. \$0.09, \$0.30, \$0.11
- C. \$0.47, \$0.58, \$0.23
- D. \$0.015, \$0.07, \$0.03

Do you have to calculate all three?

25. A water treatment facility has 2 filters that each measure 16 feet wide, 16 feet long, and 12 feet deep. The plant treats 6.0 MGD. Under normal conditions (all filters in service) what is the plant's filtration rate?

- A. 8.1 gpm/ft²
- B. 10 gpm/ft²
- C. 21 gpm/ft²
- D. 29 gpm/ft²

26. A jar test indicates that 50 ppm of liquid alum will provide an optimum coagulant dosage. The alum solution has a S.G. of 1.2. If the water plant treats, on average 1.8 MGD, how many pounds of alum will be used every 30 days?

- A. 27,021 lbs
- B. 22,518 lbs
- C. 19,027 lbs
- D. 14, 899 lbs

27. A water plant treats on average 6.5 MGD, and has an average incoming concentration of iron of 0.07 ppm. If 85% of the iron is removed, how many lbs. of iron will be removed in a year's time?

- A. 206 lbs
- B. 512 lbs
- C. 1177 lbs
- D. 1383 lbs

28. The chlorine demand is calculated to be 2.8 mg/l. The flow through the plant is 5000 gpm and the chlorinator was set to feed 160 lbs/day. If the desired chlorine residual leaving the plant is 0.8 ppm, what will be the new setting of the chlorinator?

- A. 100 lbs/day
- B. 120 lbs/day
- C. 160 lbs/day
- D. 216 lbs/day

29. What is the water horsepower for a pump station with the following parameters?

- A. 45 WHP
- B. 52.6 WHP
- C. 65.7 WHP
- D. 74 WHP

Flow 1.5 MGD
Pump efficiency 80%

Total head 200 ft
Motor Efficiency 90%

30. What is the brake horsepower for a pump station with the above parameters?

- A. 65.7 BHP
- B. 72 BHP
- C. 80 BHP
- D. 85.2 BHP

31. What is the motor horsepower for a pump station with parameters from question #30?

- A. 65.7 MHP
- B. 73 MHP
- C. 80 MHP
- D. 85.2 MHP

Answer Key

- 21. B
- 22. A
- 23. D
- 24. B
- 25. A
- 26. A

- 27. C
- 28. D
- 29. B
- 30. A
- 31. B

Class I & II Solved Equations

1. Conversion used: $1 \text{ MGD} = 694.5 \text{ gpm}$ You multiple because you are going from left to right on the conversion sheet.
 $1.5 \text{ MGD} \times 694.5 \text{ gpm} = 1041.8$ or 1042 gpm
2. First calculate the number of minutes in 8 hours – $8 \text{ hrs.} \times 60 \text{ min/hr.} = 480$ minutes
Next take the flow in gallons in the 8 hour period and divide by the number of minutes in 8 hours
 $2,000,000 \text{ gallons} \div 480 \text{ minutes} = 4167 \text{ gpm}$
3. Formula used: Volume, $\text{ft}^3 = 0.785 \times \text{dia, ft} \times \text{dia, ft} \times \text{length, ft}$
Calculate the diameter of the pipe in feet – $8 \text{ inches} / 12 \text{ inches/ft} = 0.67 \text{ feet}$
Now calculate the volume of the pipe – $0.785 \times 0.67 \text{ ft} \times 0.67 \text{ ft} \times 1,500 \text{ ft} = 528.6 \text{ ft}^3$
4. Conversion used: $1 \text{ ft}^3 = 7.48 \text{ gal.}$ You multiply because you are going from left to right on the conversion sheet.
 $528.6 \text{ ft}^3 \times 7.48 \text{ gal/ft}^3 = 3,953.9 \text{ gallons}$
5. Formula used: $\text{Weir Overflow Rate} = \text{Flow (gpm)} \div \text{Feet of Weir}$
A circular sedimentation tank has a weir all along the outer edge of the tank. The length of weir is equal to the tank's circumference. In this problem you are given the circumference is 300 feet.
Calculate the weir overflow rate – $400 \text{ gpm} \div 300 \text{ feet of weir} = 1.33 \text{ gpm/ft}$

6. Formula used: **Weir Overflow Rate = Flow (gpm) ÷ Feet of Weir**

Also needed: Diameter (D) = 2 x radius & Circumference = 3.14 x Diameter (D)

Diameter = 2 x 30 feet = 60 feet

Circumference = 3.14 x 60 feet = 188.4 feet

Weir Overflow Rate = 150 gpm ÷ 188.4 ft = 0.8 gpm/ft

7. Formula used: **Detention Time = Volume (gals) ÷ Flow (gpm)**

Calculate the volume of the tank

Volume (gal) = 15 ft x 25 ft x 10 ft x 7.48 gal/ft³ = 28,050 gal

Detention Time = 28,050 gal ÷ 250 gpm = 112.2 minutes

8. To solve for detention time in hours, take detention time in minutes and divide by 60 minutes/hour

Detention time (hr) = 112.2 min ÷ 60 min/hr = 1.87 hours

9. Conversion used: **MGD to gpm** – 0.4 MGD x 604.5 gpm = 277.8 gpm

Detention time = 28,050 gal ÷ 277.8 gpm = 199.97 minutes

10. Formula used: **Surface Overflow Rate = Flow (gpm) ÷ Area (ft²)**

Surface area of tank – 10 ft x 12 ft = 120 ft² (Don't use depth for ft²)

Surface Overflow Rate = 700 gpm ÷ 120 ft² = 5.8 gpm/ft²

11. Conversion used: **flow to gpm**

2 ft³/s x 448.8 gpm/ft³/s = 897.6 gpm

Surface Overflow Rate = 897.6 gpm ÷ 120 ft² = 7.48 gpm/ft²

12. Formula used: **ppm = lbs of chemical ÷ (flow, MGD x 8.34)**

ppm = 32 lbs ÷ (1.2 MGD x 8.34) = 32 ÷ 10.008 = 3.2 ppm

13. Formula used: $\text{Velocity (V)} = \text{Flow (Q)} \div \text{Area, ft}^2(\text{A})$

Find the area of the 10 in pipe - $10 \text{ in} \div 12 \text{ in} = 0.83 \text{ ft}$

Area = $0.785 \times 0.83 \times 0.83 = 0.54 \text{ ft}^2$

Velocity - $1.3 \text{ ft}^3/\text{s} \div 0.54 \text{ ft}^2 = 2.4 \text{ ft/s}$

14. Conversion used: $\text{flow from gpm to ft}^3/\text{s}$ - $400 \text{ gpm} \times 0.1338 \text{ ft}^3/\text{s} = 0.89 \text{ ft}^3/\text{s}$

Velocity - $0.89 \text{ ft}^3/\text{s} \div 0.54 \text{ ft}^2 = 1.65 \text{ ft/s}$

15. Conversion used: $\text{psi} = \text{ft of head} \times 0.433$

psi = $150 \text{ feet} \times 0.433 = 65 \text{ psi}$

16. Conversion used: $\text{psi} = \text{feet of head} \times 0.433$

psi = $(95 \text{ ft} - 5 \text{ ft}) \times 0.433$ Subtract 5 feet because gauge is 5 feet off the ground

psi = $90 \text{ ft} \times 0.433 = 39 \text{ psi}$

17. Formula used: $\text{Filtration Rate} = \text{Flow (gpm)} \div \text{Surface Area (ft}^2)$

Calculate the filtration rate - $900 \text{ gpm} \div 240 \text{ ft}^2 = 3.75 \text{ gpm/ft}^2$

18. Conversion used: $\text{flow to MGD to gpm}$ - $2.1 \text{ MGD} \times 694.5 \text{ gpm/MGD} = 1,458.45 \text{ gpm}$

Filtration Rate = $1,458.45 \text{ gpm} \div 240 \text{ ft}^2 = 6.07 \text{ gpm/ft}^2$

19. Formulas used: $\text{ppm} = \text{pounds} \div (\text{Flow, MGD} \times 8.34)$ and

$\text{Residual} = \text{Dosage} - \text{Demand}$

Calculate ppm - $10 \text{ pounds} \div (0.25 \text{ MGD} \times 8.34) = 10 \div 2.085 = 4.8 \text{ mg/L}$

Calculate Residual - $\text{Residual} = 4.8 \text{ mg/L} - 3.0 \text{ mg/L} = 1.8 \text{ mg/L}$

20. Formula used: **Pounds = (ppm x 8.34 x Flow, MGD) ÷ % purity**

Convert 900,000 gal/day to MGD – $900,000 \div 1,000,000 = 0.9$ MGD

Convert %purity to decimal – $5.25\% \div 100 = 0.0525$

Calculate pounds – $(3 \text{ ppm} \times 8.34 \times 0.9 \text{ MGD}) \div 0.0525 = 22.52 \div 0.0525 = 428.9$ pounds

Class III & IV Solved Equations

21. Formula used: **Filtration Rate : For every 1.6 in./min. of rise or fall = 1 gpm/ft²**

Backwash cycle raises the water level 6 in. in 3 min.

Rise per min. = $6 \text{ in.} \div 3 \text{ min.} = 2 \text{ in./min}$
 $2 \text{ in./min} \div 1.6 = 1.25 \times 1 \text{ gpm/ft}^2 = 1.25 \text{ gpm/ft}^2$

22. Formula used: **Detention Time = Volume of basin (gal) ÷ Flow (gpm)**

First calculate the volume in gallons for the two basins

Flocculator volume (gal) = $20' \times 60' \times 15' \times 7.48 \text{ gal/ft}^3 = 134,640$ gallons

Sedimentation basin (gal) = $40' \times 90' \times 15' \times 7.48 \text{ gal/ft}^3 = 403,920$ gallons

Total Basin volume – $134,640 + 403,920 = 538,560$ gallons

Convert flow to gpm – $5.2 \text{ MGD} \times 694.5 \text{ gpm/MGD} = 3,611.4$ gpm

Divide tank volume (gal) by flow in gpm = $538,560 \text{ gal} \div 3,611.4 = 149.1$ or 149 minutes

23. Formula used: **ppm = pounds ÷ (flow, MGD x 8.34)**

Since you have pounds already you do not have to use SP.GR. in the calculation.

ppm = $110 \text{ lbs.} \div (6.9 \text{ MGD} \times 8.34) = 110 \div 57.546 = 1.9$

24. Formula used: **Formula not on sheet**. Take the old price x (1 + the percent change in decimal format)

$$\text{Alum price} = \$0.08 \times 1.12 = \$0.09/\text{lb}$$

$$\text{Polymer price} = \$0.22 \times 1.37 = \$0.30/\text{lb}$$

$$\text{Electrical cost} = \$0.08 \times 1.41 = \$0.11/\text{kWh}$$

25. Formula used: **Filtration rate = Flow (gpm) ÷ Filter surface area (ft²)**

$$\text{Convert flow from MGD to gpm} - \text{Flow} = 6.0 \text{ MGD} \times 694.5 \text{ gpm/MGD} = 4,167 \text{ gpm}$$

$$\text{Calculate area of filters} - \text{Area (ft}^2\text{)} = 2 \text{ filters} \times 16' \times 16' = 512 \text{ ft}^2$$

$$\text{Calculate Filtration Rate} = 4,167 \text{ gpm} \div 512 \text{ ft}^2 = 8.1 \text{ gpm/ft}^2$$

26. Formula used: **Pounds = ppm x 8.34 x flow, MGD x Sp.gr. x # of days**

$$\text{Pound} = 50 \text{ ppm} \times 8.34 \times 1.8 \text{ MGD} \times 1.2 \times 30 \text{ days}$$

$$\text{Pounds} = 27,021 \text{ pounds}$$

27. Formula used: **pounds = ppm x 8.34 x MGD x % removal x days in a year**

$$\text{Pounds removed} = 0.07 \times 8.34 \times 6.5 \text{ MGD} \times 0.85 \times 365 \text{ days} = 1,177 \text{ pounds removed in 1 year}$$

28. Formulas used: **Dosage = Demand + Residual Pounds = ppm x 8.34 x flow, MGD**

$$\text{Calculate Dosage- Dosage, mg/L} = 2.8 \text{ mg/L} + 0.8 \text{ mg/L} = 3.6 \text{ mg/L}$$

$$\text{Convert flow from gpm to MGD} - \text{flow, MGD} = 5000 \text{ gpm} \div 694.5 \text{ gpm/MGD} = 7.19 \text{ MGD}$$

$$\text{Calculate Pounds} = 3.6 \text{ mg/L} \times 8.34 \times 7.19 \text{ MGD} = 215.87 \text{ pounds}$$

The chlorinator must be set to 216 lbs/day.

Given the following:

$$\text{Flow} = 1.5 \text{ MGD}$$

$$\text{Total Head} = 200 \text{ ft}$$

$$\text{Pump efficiency} = 80\%$$

$$\text{Motor efficiency} = 90\%$$

29. Formula used: $\text{Water horsepower} = (\text{flow, gpm} \times \text{total head, ft}) \div 3960$

Convert flow to gpm – $\text{Flow, gpm} = 1.5 \text{ MGD} \times 694.5 \text{ gpm/MGD} = 1,041.75 \text{ gpm}$

$\text{WHP} = (1,041.75 \text{ gpm} \times 200 \text{ ft}) \div 3960 = 208,350 \div 3960 = 52.6 \text{ WHP}$

30. $\text{Brake Horsepower} = (\text{flow, gpm} \times \text{Total head, ft}) \div (3960 \times \text{Pump Efficiency})$

$\text{BHP} = (1,041.75 \times 200 \text{ ft}) \div (3960 \times 0.80) = 208,350 \div 3,168 = 65.7 \text{ BHP}$

31. $\text{Motor Horse Power} = (\text{flow, gpm} \times \text{Total head, ft}) \div (3960 \times \text{Pump Efficiency} \times \text{Motor Efficiency})$

$\text{MHP} = (1,041.75 \text{ gpm} \times 200 \text{ ft}) \div (3960 \times 0.80 \times 0.90) = 208,350 \div 2,851.2 = 73 \text{ MHP}$



Questions or Concerns?

The Kentucky Operator Certification Program provides training and issues certifications to ensure that individuals engaged in performing many of Kentucky's critical environmental activities are qualified and capable to perform their duties. DCA staff are available to provide on-site assistance and training.

Online: eec.ky.gov

Phone: 502-782-6189

E-mail: envhelp@ky.gov



Kentucky Division of Compliance Assistance

Certification and Licensing Branch

300 Sower Boulevard, 1st Floor, Frankfort, KY 40601

Assistance Hotline: envhelp@ky.gov | 502-782-6189